

**SAFETY PERMIT: HOT WORK**

This permit is issued subject to Hot Work Safety Policy GABD and the rules shown below.

W.O. Number: \_\_\_\_\_ Date: \_\_\_\_\_

Work Description: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

The job location has been examined and found to be safe. A watchperson with a suitable fire extinguisher has been assigned to the job and has been instructed as per policy.

Verified By: \_\_\_\_\_ Date: \_\_\_\_\_  
Person Performing Work

Verified By: \_\_\_\_\_ Date: \_\_\_\_\_  
Operations Management

Verified By: \_\_\_\_\_ Date: \_\_\_\_\_  
Location Management

**Emergency Contact Numbers:**

- 1. Fire Department: \_\_\_\_\_
- 2. Operations Department: \_\_\_\_\_
- 3. Location Managerial Authority: \_\_\_\_\_

**Rules:**

- 1. Cover or remove combustible materials within 30 feet (10 meters). Special precautions are needed for elevated work to ensure that combustibles on lower levels are protected.
- 2. Determine contents of tanks or containers before performing any type of hot work on or to them.
- 3. Warn persons in or below the work area before proceeding with work.
- 4. Watchmen must stay on the job for 30 minutes after hot work is completed and must inspect the hot work and surrounding area for any evidence of combustion prior to ending their watch.
- 5. Do not cut or weld over wood surfaces unless they are wetted down, wetting down must also take place at the completion of the hot work.
- 6. This permit must be posted within 30 feet of work area.
- 7. Persons involved in the carrying out of the hot work, including those acting as watch persons, must be advised of the response procedure in the event of an emergency relating to this work.